

AWTA PRODUCT TESTING

Australian Wool Testing Authority Ltd - trading as AWTA Product Testing

A.B.N 43 006 014 106

1st Floor, 191 Racecourse Road, Flemington, Victoria 3031

P.O Box 240, North Melbourne, Victoria 3051

Phone (03) 9371 2400 Fax (03) 9371 2499

TEST REPORT

Client : James Dunlop
39 Peterborough Street
Christchurch New Zealand
New Zealand

Test Number : 16-002770
Issue Date : 01/06/2016
Print Date : 1/06/2016

Sample Description Clients Ref : "Stallion Two"
Textural plain woven fabric with Calandered finish
Colour : Aubergine
End Use : Drapery
Nominal Composition : 100% Polyester
Nominal Mass per Unit Area/Density : 232g/m2

AS 1530.2-1993

**Methods for Fire Tests on Building Materials, Components and Structures.
Part 2: Test for Flammability of Materials**

Date Tested		31/05/2016
Flammability Index		2
	Length	Width
Spread Factor	1	1
Heat Factor	1	1
Maximum height (d)		
Mean	3.5	3.5
Coefficient of Variation	61.9	35.0 %
Heat (a)		
Mean	2.8	3.3 °C.min
Coefficient of Variation	72.8	42.2 %
Number of Specimens Tested	9	9
Observation	Visible smoke,melting and flaming debris	

These test results relate only to the behaviour of the test specimens of the material under the particular conditions of the test, and they are not intended to be the sole criterion for assessing the potential fire hazard of the material in use.

60495

12592

Page 1 of 1

© Australian Wool testing Authority Ltd
Copyright - All Rights Reserved



Accredited for compliance with ISO/IEC 17025

- Chemical Testing
- Mechanical Testing
- Performance & Approvals Testing

: Accreditation No. 983
: Accreditation No. 985
: Accreditation No. 1356

Samples and their identifying descriptions have been provided by the client unless otherwise stated. AWTA Ltd makes no warranty, implied or otherwise, as to the source of the tested samples. The above test results relate only to the sample or samples tested. This document shall not be reproduced except in full and shall be rendered void if amended or altered. This document, the names AWTA Product Testing and AWTA Ltd may be used in advertising providing the content and format of the advertisement have been approved by



0204/11/06

APPROVED SIGNATORY

MICHAEL A. JACKSON B.Sc.(Hons)
MANAGING DIRECTOR